

A Study on the Solar Correction for the RS41 using the Upper Air Simulator at KRISS

Yong-Gyoo Kim* and Upper air measurement team

Center for Thermometry and Fluid Flow


Korea Research Institute of Standards and Science (KRISS)

Daejeon, Korea

*dragon@kriss.re.kr

Calibration of radiosonde


- In common, calibration has been done at ground laboratory.
- ◆ Calibration of Temperature, Humidity and Pressure **at static conditions**
 - It cannot reflect the upper air conditions.
- ◆ In case of **temperature measurement**,
 - Ventilation, low pressure and solar radiation effects should be counted for the precise calibration.
 - Ventilation can decrease the air thermometer reading.
 - Solar radiation (radiation cooling) can increase (decrease) the sensor temperature.
 - Low pressure, so-called low air density, can enhance the solar radiation effects.
- ◆ **It is necessary to make more realistic test systems and procedures for calibration of radiosonde.**
- Recently **KRISS developed the Upper Air Simulator for calibration of radiosonde** in 2018.



In this presentation

- Introduction of **UAS** and its operating features using a **RS41** tested at conditions of:
 - ◆ Temperature from -70 °C to 20 °C
 - ◆ Pressure range from 7 hPa to 100 hPa
 - ◆ Solar radiation at 900 W/m²
 - ◆ Wind ventilation from 4 to 6.5 m/s
- Estimation of solar correction formula and comparison with the measured sounding data of CoreTemp2017 at Lindenberg



Schematic design of UAS






5 main components

- ◆ **Climate chamber** to control temperature (Capacity: $-70\text{ }^{\circ}\text{C} \sim 90\text{ }^{\circ}\text{C}$)
- ◆ High pressure **dry air generator** (Capacity: 6 atm, $-80\text{ }^{\circ}\text{Cdp}$)
- ◆ **Solar simulator** to mimic radiation (Capacity: $0 \sim 1500\text{ W/m}^2$)
- ◆ **Sonic nozzle** to make air ventilation (Capacity: $3\text{ m/s} \sim 6.5\text{ m/s}$)
- ◆ **Vacuum pump** to control pressure (Capacity: $3\text{ hPa} \sim 1000\text{ hPa}$)

View of UAS components




Hot air blower
to protect frost




Air Temperature


Cooling processes



Temperature stability inside chamber@-70 °C set



- Type E thermocouple
- Stability of ± 0.1 °C
- Gradient of ± 0.4 °C



Reference air temperature

- PT100 thermometer
- Uncertainty of 50 mK($k=2$)
- **Stability of ± 0.01 °C**



Wind ventilation

□ Mass flow control using sonic nozzle





◆ Five set of nozzle diameter (d)

- (0.2, 0.28, 0.4, 0.8, 1.12, 3.2) mm

◆ 3 m/s ~ 6.5 m/s @(3 ~ 500) hPa

- Set accuracy of ± 0.05 m/s


◆ Stability of ± 0.02 m/s



Pressure

□ Vacuum gauge

- ◆ INFICON CDG 020D
- ◆ (10 ~ 1000) torr
- ◆ 1 % of reading accuracy




Stability of ± 0.1 hPa

Solar Irradiance




☐ Solar simulator

- ◆ Newport Research Xe Arc Lamp
- ◆ Max. 1000 W with ozone-free Xe
- ◆ Tested at irradiance ($\sim 900 \text{ W/m}^2$)
- ◆ Calibration with a reference pyranometer
- ◆ **Stability of $\pm 1.5 \text{ W/m}^2$**




Reference
pyranometer

<Uniformity check: within $\pm 5 \%$ >




Setup of RS41

- ❑ **Vaisala RS41** and **MW41** sounding system
 - ◆ **Direct exposure** to the radiation (Perpendicular to the beam direction)
 - Expose for 3 min
- ❑ Measurement in remote mode using the MW41.




-40 °C set, 10 hPa, 5 m/s, 900 W/m²



P-T matrix



T \ P	7 hPa	10 hPa	30 hPa	60 hPa	100 hPa
-70 °C	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s
-55 °C	$v=5$ m/s	$v=5$ m/s	$v =$		$v=5$ m/s
			0	4	
			5	6.5	
-40 °C	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s
-20 °C	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s
0 °C	$v=5$ m/s	$v=5$ m/s	$v =$		$v=5$ m/s
			0	4	
			5	6.5	
20 °C	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s	$v=5$ m/s

Solar heating behavior with pressure





- As pressure decreases, degree of solar heating become larger.
 - ◆ At 7 hPa and -70 °C, temperature rising of about 1.0 °C was observed.
 - ◆ At higher pressure of 100 hPa, degree of temperature rising decreased to about 0.4 °C.
- Stronger air convection at higher pressure may reduce the temperature rising.

Solar heating behavior with temperature





- At low pressure, solar heating increases as temperature decreases.
 - ◆ At 7 hPa, about 0.15 °C temperature difference was observed with temperature.
 - ◆ At 100 hPa, there was no clear temperature effects.
- This may be related to the change of long wave radiation from the sensor with temperature ($E_{rad} = \sigma \epsilon T^4$) under low influence of convection.

Solar heating behavior with ventilation speed



- For RS41, ventilation effects are not so big.
- ◆ As speed increases, solar heating slightly decreases.
- ◆ With pressure change at same temperature, similar behavior was observed.
- ◆ The temperature dependence of ventilation speed is nearly same with the temperature.

Temperature rise of RS41 with P and v



$$(T_{\text{on}} - T_{\text{off}})_{PT} = S/900 \times \{y_0(T) + A_0(T) \exp(-P/p_0(T))\}$$

Temperature and pressure effect

S : solar irradiance (W/m^2)
 y_0 , A_0 , p_0 : fitting coefficients


$$(T_{\text{on}} - T_{\text{off}})_V = S/900 \square \{-0.014(v - 5)\}$$

Ventilation effect


S : solar irradiance (W/m^2)
 v : ventilation speed (m/s)

$$(T_{\text{on}} - T_{\text{off}})_{\text{Total}} = S/900 \square \{y_0(T) + A_0(T) \exp(-P/p_0(T)) - 0.014(v - 5)\}$$


Estimation of fitting error



Comparison with CoreTemp2017 data



- Measured spectrum with the altitude



- In stratosphere, good agreement.
- In troposphere, more studies required.

Much wider pressure dependence tests are required.

Summaries

- ❑ **Solar irradiance test for the Vaisala RS41** was conducted in the stratospheric region using the **KRISS Upper Air Simulator (UAS)**.
 - ◆ Temperature of -70 °C to 20 °C and pressure of 7 hPa to 100 hPa under solar irradiance of 900 W/m² at various ventilation speed of (4 to 6.5) m/s
 - ◆ In addition to pressure and wind ventilation, it has been shown experimentally that temperature have to be taken into account.
 - ◆ It is possible to create a solar radiation correction formula from the measured data.
 - ◆ Solar correction data from UAS were in good agreement with CoreTemp 2017 data in the stratosphere region.
- ❑ In order to get more accurate results, UAS will be improved from the following point of view. (Now it is underway!)
 - ◆ Sensor boom tilt
 - ◆ Rotation of the sensor boom
 - ◆ Change of exposed area of sensor boom
- ❑ **With UAS, it will be able to calibrate all types of radiosondes with traceability to international measurement standards.**

Thank you for your attention

And

Thank my team!

